

Technical Bulletin TB2017-01

March 2017 FlashShield Design & Installation Guide

April 26, 2017

This Technical Bulletin provides an outline of the main updates in the *March 2017 FlashShield Design and Installation Guide*. Please use this technical bulletin as a reference, and review the following changes in entirety, within the March 2017 Guide.

- Sec. 1.1 has been updated to include additional information on corrosive threats to steel and brass.
- Sec. 4.2.3, the ‘FS-Series’ fitting assembly instructions have been removed.
- Sec. 4.6.4.f. (gas fireplaces) has been updated to include the new ANSI LC 1 instructions requirement that, *CSST shall not enter the metallic cabinet of an appliance utilizing a metallic vent which penetrates through a rooftop.*
- Table 4-10, *Largest Single Appliance Served by Regulator*, data has been updated.
- Certification test questions #14, 15, and 23 have been adjusted.

The *FlashShield On-line Certification* course has also been updated to reflect these changes.

The March 2017 FlashShield Design & Installation Guide is shipping as of April 27, 2017.