



Certificate of Compliance

Certificate: 2728525

Master Contract: 249607

Project: 80037580

Date Issued: 2020-04-30

Issued To: Gastite Division of Titeflex Corp
1116 Vaughn Dr
Portland, Tennessee, 37148
United States

Attention: Jordan Strunk

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.

Issued by: *John Kristoff-Kichka*
John Kristoff-Kichka



PRODUCTS

CLASS - C333504 - SYSTEMS (GAS) Fuel Piping

CLASS - C333584 - SYSTEMS (GAS) Fuel Piping-Certified to U.S. Standards

Model Number	Pressure Rating	Trade Name: Gastite	Size
S93-6A, S93-6A4	25		3/8
S93-8A, S93-8A4	25		1/2
S93-11B, S93-11B4	25		3/4
S93-16A, S93-16A4	25		1
S93-20A, S93-20A4	25		1 1/4
S93-24A, S93-24A4	25		1 1/2
S93-32A, S93-32A4	25		2

Trade Name: FlashShield



Certificate: 2728525
Project: 80037580

Master Contract: 249607
Date Issued: 2020-04-30

Model Number	Pressure Rating	Size
FS-8	25	1/2
FS-11	25	3/4
FS-16	25	1
FS-20	25	1 1/4
FS-24	25	1 1/2
FS-32	25	2

	Trade Name:	
FSP-8	25	1/2
FSP-11	25	3/4
FSP-16	25	1
FSP-20	25	1-1/4
FSP-24	25	1-1/2
FSP-32	25	2

FS-X CSST with the trade name **FlashShield** has been evaluated and listed by CSA to the optional Arc Resistant (AR) CSST Tests, Sec. 5.16 of ANSI LC1/CSA 6.26.

FSP-X CSST with the trade name **FlashShield+** has been evaluated and listed by CSA to the optional Arc Resistant (AR) CSST Tests, Sec. 5.16 of ANSI LC1/CSA 6.26.

The sizing tables for Corrugated Stainless Steel Tubing (CSST), operating at pressures over 10 psig have been verified by CSA as part of the certification program. The sizing tables are provided by the manufacturer for engineering guidance

APPLICABLE REQUIREMENTS

ANSI LC 1-2018•CSA 6.26-2018 Fuel Gas Piping Systems Using Corrugated Stainless Steel Tubing



Supplement to Certificate of Compliance

Certificate: 2728525

Master Contract: 249607

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
80037580	2020-04-30	Update Report Number 2728525 to add FlashShield Plus models, FSP-24 and FSP-32 using the XR3 REV2 Series End Fittings. Prepare ICC-ES Report from Custom Project #80037581. Prepare IAPMO Report from Custom Project #80037582 for Report #2728525.
80017309	2019-11-15	Add a new FlashShield+ Model, FSP-20 (1-1/4") using XR3-Series End Fittings.
000070195969	2018-11-29	New Layer Structure Construction for the FlashShield+ Models, FSP-8, FSP-11, FSP-16 using the XR3-Series End Fittings.
000070144584	2017-08-30	New Formulation of the Flame Retardant Polyolefin for FS Series Hose (Titeflex Poly5). Reference TMH 1085 Rev. B.
000070119718	2017-03-21	Update to ANSI LC1-2016/CSA 6.26-2016 per Gas Products Notice No. 399. Update Installation Guides and drawings.
000070066234	2016-03-11	Change in the outer black Polyblend jacket layer See Gastite TMH 1085 specification document for details
000070044017	2015-09-24	Update training/installation/user manuals to ANSI LC1-2014
0002750055	2014-12-23	Add Lakeshore Fittings as maker of the end fittings for the CSST
0002728525	2014-07-25	Transfer certificate 1009875 from Titeflex Corporation MC 188978 to Gastite Division of Titeflex .