

Technical Bulletin TB2016-01

May 17, 2016

Gastite, and FlashShield ratings to ASTM E84 (UL 723), and CAN/ULC S102.2, *Standard Test Methods for Surface Burning Characteristics of Building Materials*

Gastite and FlashShield flexible gas piping systems meet the requirements of 25 flame spread index and 50 smoke developed index when tested in accordance with ASTM E84 (UL 723), and also CAN/ULC S102.2.

Therefore, Gastite and FlashShield gas piping may be routed through typical building construction including plenums, floor and ceiling joists, rim joists, walls, or other fire rated construction limited to materials rated to 25/50 or better for flame spread, and smoke developed index, when tested to ASTM E84, or CAN/ULC S102.2.